



Certificate of Conformity

Certificate No.: 2088AP0401N031001
Equipment: PV inverter
Brand Name: 
Test Model No.: ASW3000-T, ASW4000-T, ASW5000-T, ASW6000-T
Applicant: AISWEI New Energy Technology(Jiangsu) Co.,Ltd
Building 9, No.198 Xiangyang Road, 215011 Suzhou, P.R.China
Report No.: PVBE200401N031

Use in accordance with regulations:

Automatic disconnection device with single -phase mains surveillance in accordance with C10/11:2019 for photovoltaic systems with a single -phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. It replaces the disconnection device with an insulating function, which the distribution network provider can access at any time.

Applied rules and standards

EN 50549-1:2019

Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network - Generating plants up to and including Type B

C10/11:2019

Specific technical prescriptions regarding Power-Generating plants operating in parallel to the distribution network

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Name: James Huang
Technical Manager/ New Energy Team
Date: 2020-07-16

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.