

Certificate of Conformity

By the product certificate number:		No. 2621/0275-A-E1-CER			
Issued to:					
License holder:	AISWEI Technology Co., Ltd. Room 905B, 757 Mengzi Road, Huangpu District, 200023 Shanghai, P.R. China.				
Trademark:					
Manufacturer:	AISWEI New Energy Technology (Ya No.588 Gangxing Road Yangzhong Zhe				
It is certified that th	e product:				
Type of generating unit: PV Grid-tied Inverter					
Models:	ASW20K-LT-G2 / ASW17K-LT-G2 / ASW15 ASW10K-LT-G2 / ASW8K-LT-G2	K-LT-G2 / ASW13K-LT-G2 / ASW12K-LT-G2 /			
Technical Data:	Nominal power [W]	See page 2			
	Nominal voltage [V]	400 (3~/N/PE)			
	Nominal frequency [Hz]	50 Hz / 60 Hz			
	Firmware version	E1.00			
	Number of phases	Tree Phases			
Section of the sectio	Isolation Transformer	No			

Is in compliance with the standard:

IEC 61727: 2004.

Photovoltaic (PV) systems - Characteristics of the utility interface.

This certificate is based upon the test results of the Test Report GZES230300477801.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-32 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate supersedes the certificate nº 2621/0275-A-CER.

First issued on 25th April 2023. This certificate is valid until 17th September 2024

Madrid, 25th April 2023

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A.U. C/ Trespaderne, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at <u>www.sgs.com/terms.and</u> conditions. The status and validity of the certificate can be checked scanning the QR code above included or through the following web <u>link</u>. This document cannot be reproduced partially

SGS





No. 2621/0275-A-E1-CER Page 1 of 2



Full list of product references and nominal characteristics:

Product Model	ASW20K-LT- G2	ASW17K-LT- G2	ASW15K-LT- G2	ASW13K-LT- G2	
Input (DC)					
Max.DC Voltage (V)	1100				
Rated input voltage (V)	630				
MPPT Voltage Range (V)	150 ~ 1000				
Max. input current per MPPT (A)	26 + 26				
Output (AC)					
Max AC Output power (kVA)	20	17	15	13	
Rated AC Output power (kW)	20	17	15	12	
Rated AC Output Current (A)	29.0	24.6	21.7	18.8	
Nominal Grid Voltage (V)	400 (3~/N/PE)				
Nominal Frequency (Hz)	50 / 60				

Product Model	ASW12K-LT-G2	ASW10K-LT-G2	ASW8K-LT-G2		
Input (DC)					
Start-up input voltage (V)	180				
Rated input voltage (V)	630				
MPPT Voltage Range (V)	150 ~ 1000				
Max. input current per MPPT (A)	26 + 26 26 + 13				
Output (AC)					
Max AC Output power (kVA)	12	10	8		
Rated AC Output power (kW)	12	12 10			
Rated AC Output Current (A)	17.4	14.5	11.6		
Nominal Grid Voltage (V)	400 (3~ /N/PE)				
Nominal Frequency (Hz)	50 / Hz				



SGS Tecnos, S.A.U. C/ Trespaderne, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at <u>www.sgs.com/terms_and_conditions</u>. The status and validity of the certificate can be checked scanning the QR code above included or through the following web <u>link</u>. This document cannot be reproduced partially

SGSSG