

No. 2622/0301-B-CER

Certificate of Conformity

By the product certificate number:

Issued to:

License holder:

AISWEI Technology (Shanghai) Co., Ltd.

Room 905B, 757 Mengzi Road, Huangpu District,

200023 Shanghai, P.R. China

Trademark:

👍 Solplanet

Manufacturer:

AISWEI New Energy Technology (YangZhong) Co., Ltd. No. 588 Gangxing Road, Yangzhong, Zhenjiang, China

It is certified that the product:

Type of generating unit:

Grid-connected PV Inverter

Models:

ASW25K-LT-G3 / ASW27K-LT-G3 / ASW30K-LT-G3 / ASW33K-LT-G3 / ASW36K-LT-G3 / ASW40K-LT-G3

Technical Data:

Nominal power [W]

See page 2

Nominal voltage [V]

230 / 400

Nominal frequency [Hz]

50

Firmware version

Master Firmware version: V610-03041-05 Slave Firmware version: V610-60009-00 Safety Firmware version: V610-11007-02

Number of phases

Three Phases

Isolation Transformer

No

Is in compliance with the standard:

IEC 61683:1999.

Photovoltaic systems. Power conditioners. Procedure for measuring efficiency.

This certificate is based upon the test results of the Test Report GZES220400574702

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-33 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 30th June 2022 This certificate is valid until 30th June 2027

Madrid, 30th June 2022

Daniel Arranz Muñiz Certification Manager











Full list of product references and nominal characteristics:

Product Model	ASW25K-LT-G3	ASW27K-LT-G3	ASW30K-LT-G3			
Input (DC)						
Max.DC Voltage (V)	Manage and the	1100				
MPPT Voltage Range (V)		180 ~ 1000				
Full load DC voltage range (V)		450 ~ 850				
Max. input current (A)	32/32/32					
	Output (A0	C)				
Rated active power (W)	25000	27000	30000			
Max. apparent AC power (VA)	27500	29700	33000			
Max. Output Current (A)	39.9	43.0	47.8			
Nominal Grid Voltage (V)	230 / 400 (3 /N/PE)					
Nominal Frequency (Hz)	50					

Product Model	ASW33K-LT-G3	ASW36K-LT-G3	ASW40K-LT-G3			
Input (DC)						
Max.DC Voltage (V)	\$64.0503656565655655656565656565656565656565	1100				
MPPT Voltage Range (V)	16 100000 103000000000000000000000000000	180 ~ 1000				
Full load DC voltage range (V)		450 ~ 850				
Max. input current (A)	32/32/40					
	Output (A0	C)				
Rated active power (W)	33000	36000	40000			
Max. apparent AC power (VA)	36300	39600	44000			
Max. Output Current (A)	52.6	57.4	63.8			
Nominal Grid Voltage (V)		230 / 400 (3 /N/PE)	(5551505) (5551505)			
Nominal Frequency (Hz)	50					







Summary efficiency results measured for the tested models:

These efficiency results are representatives for the referred models with a testing frequency of 50Hz.

Power conditioner type - Grid Connected

ASW25K-LT-G3							
Test condition 10%Sn 25%Sn 50%Sn 75%Sn 100%Sn							
Minimum rated input voltage (1)	94.6%	96.4%	96.9%	97.1%	96.8%		
Nominal input voltage (2)	97.0%	97.8%	98.0%	98.1%	98.0%		
90% of the maximum rated input voltage (3)	94.6%	97.1%	97.3%	97.6%	97.4%		

(1) 450 V; (2)630 V; (3)850 V

ASW27K-LT-G3							
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn		
Minimum rated input voltage (1)	94.9%	96.4%	97.0%	97.0%	96.8%		
Nominal input voltage (2)	97.0%	97.7%	98.0%	98.1%	97.9%		
90% of the maximum rated input voltage (3)	94.9%	97.2%	97.2%	97.4%	97.3%		

(1) 450 V; (2)630 V; (3)850 V

ASW30K-LT-G3							
Test condition 10%Sn 25%Sn 50%Sn 75%Sn 100%Sn							
Minimum rated input voltage (1)	94.9%	96.5%	97.0%	96.7%	96.5%		
Nominal input voltage (2)	97.3%	97.6%	98.2%	98.0%	97.8%		
90% of the maximum rated input voltage (3)	95.3%	97.1%	97.6%	97.4%	97.2%		

(1) 450 V; (2)630 V; (3)850 V

ASW33K-LT-G3							
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn		
Minimum rated input voltage (1)	94.8%	96.4%	96.7%	96.7%	96.6%		
Nominal input voltage (2)	97.3%	97.8%	98.0%	98.1%	97.9%		
90% of the maximum rated input voltage (3)	94.9%	96.9%	97.4%	97.4%	97.4%		

(1) 450 V; (2)630 V; (3)850 V

ASW36K-LT-G3						
Test condition 10%Sn 25%Sn 50%Sn 75%Sn 100%						
Minimum rated input voltage (1)	95.1%	96.6%	96.7%	96.7%	96.6%	
Nominal input voltage (2)	97.4%	98.2%	98.2%	98.0%	97.8%	
90% of the maximum rated input voltage (3)	95.3%	96.9%	97.4%	97.4%	97.2%	

(1) 450 V; (2) 630 V; (3) 850 V

ASW40K-LT-G3							
Test condition 10%Sn 25%Sn 50%Sn 75%Sn 100%S							
Minimum rated input voltage (1)	95.3%	96.8%	97.0%	96.7%	96.3%		
Nominal input voltage (2)	97.7%	97.6%	98.1%	97.9%	97.6%		
90% of the maximum rated input voltage (3)	95.7%	97.1%	97.5%	97.4%	97.1%		

(1) 450 V; (2)630 V; (3)850 V



